

CE CERTIFICATE

Notified Body No. 0370

No. **0370-CPR-3208**

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation *305/2011/EU* of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

POWER, CONTROL AND COMMUNICATION CABLES. CABLES FOR GENERAL APPLICATIONS IN CONSTRUCTION WORKS SUBJECT TO REACTION TO FIRE REQUIREMENTS.

FAMILY: **300/500 V. Z1Z1-K, LiHH, HSLM** CLASSIFICATION: **Cca-s1b,d0,a1**

Place on the market under the name of:

PVS NV

VELDSTRAAT 99
3500 HASSELT (BELGIUM)

And produced in the manufacturing plant:

20/32302400

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZZ of the standard

EN 50575:2014, EN 50575:2014/A1:2016

under system 1+ are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 25th January 2019 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed and modified on 8th January 2021.

The monitoring assessment will be done before 31st December 2021

Bellaterra, 8th January 2021


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with the number of certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products



0370-CPR-3208

DESIGNATION	Z1Z1-K/LIHH/HSLH-(300/500V)
TRADE MARKS	CLS215-Cca CLS225-Cca CLS240-Cca CLS440-Cca CLS840-Cca
REACTION TO FIRE CLASS	Cca-s1b, d0, a1

CROSS SECTIONAL RANGE	RATED VOLTAGE
Conductor of 0,5 mm ² (From 2 to 61 conductors); Conductor of 0,75 mm ² (From 2 to 61 conductors); Conductor of 1 mm ² (From 2 to 61 conductors); Conductor of 1,5 mm ² (From 2 to 30 conductors); Conductor of 2,5 mm ² (From 2 to 30 conductors); Conductor of 4 mm ² (From 2 to 14 conductors); Conductor of 6 mm ² (From 2 to 10 conductors); Conductor of 10 mm ² (From 2 to 7 conductors); Conductor of 16 mm ² (From 2 to 7 conductors).	300/500 V